



中国国家强制性产品认证证书

证书编号: 2003010305073836

委托人名称、地址

欧姆龙自动化(中国)有限公司
上海市外高桥保税区爱都路253号4号楼第4层B1-1部位 200131

生产者(制造商)名称、地址

欧姆龙株式会社
日本京都市下京区盐小路通堀川东入

生产企业名称、地址

东乡电机制作所株式会社
鸟取县东伯郡汤梨浜町大字門田906-1

产品名称和系列、规格、型号

安全门开关

D4BL;Ui:300V;Ith:10A;AC-15:250V/3A, 115V/6A;IP67;型号解释详见附件

产品标准和技术要求

GB 14048.5-2008

上述产品符合强制性产品认证实施规则
CNCA-C03-02: 2014的要求, 特发此证。

发证日期: 2015年07月30日

有效期至: 2020年07月30日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书为变更证书, 证书首次颁发日期: 2003年08月01日

本证书的相关信息可通过国家认监委网站www.cnca.gov.cn查询



主任:

中国质量认证中心

中国·北京·南四环西路188号9区 100070

<http://www.cqc.com.cn>



Q 1069383



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

No. : 2003010305073836

NAME AND ADDRESS OF THE APPLICANT

OMRON INDUSTRIAL AUTOMATION (CHINA) CO., LTD
4TH FLOOR OF NO. 4 BUILDING, NO. 253 AI DU ROAD, WAIGAOQIAO FREE TRADE
ZONE, SHANGHAI, CHINA (200131)

NAME AND ADDRESS OF THE MANUFACTURER

OMRON CORPORATION
Shiokoji Horikawa Shimogyo-Ku, KYOTO, JAPAN

NAME AND ADDRESS OF THE FACTORY

Togo Electronics Works Co., Ltd.
906-1 Kadota, Yurihama - cho, Tohaku - gun, Tottori - ken, 689-0736,
JAPAN

NAME, MODEL AND SPECIFICATION

Safety Door Switch

D4BL;Ui:300V;Ith:10A;AC-15:250V/3A, 115V/6A;IP67;See the Appendix

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB 14048.5-2008

This is to certify that the above mentioned products have met the
requirements of implementation rules for compulsory certification(REF
NO. CNCA-C03-02:2014).

Date of issue: Jul. 30, 2015 Date of expiry: Jul. 30, 2020

Validity of this certificate is subject to positive result of the regular
follow up inspection by issuing certification body until the expiry date.

Date of original certification: Aug. 01, 2003

This certificate can be verified through CNCA's website: www.cnca.gov.cn



President:

Wang Kejiao

CHINA QUALITY CERTIFICATION CENTRE

Section 9, No. 188, Nansihuan Xilu, Beijing 100070 P.R. China

<http://www.cqc.com.cn>



Q 1069383



中国国家强制性产品认证证书

附录:

第 1 页 共 2 页

证书编号: 2003010305073836

纸号: 1069383

型号的解释(Explanation of model/ type):

D 4 B L - □ □ □ □ - □ □ - □

1 2 3 4 5 6 7 8

1. 基本型号

D 4 B L: 电磁锁定·安全门开关

2. 导线孔尺寸(2导线孔)

1: PG13.5

2: G1/2

3: 1/2-14NPT

4: M20

3. 内置开关

C: 1NC/1NO(慢速)+1NC(慢速)

D: 2NC(慢速)+1NC(慢速)

G: 2NC(慢速)+2NC(慢速)

4. 头部安装方向

L: 左面

R: 右面

F: 正面

B: 背面

5. 门锁定/释放方式(配有标准的专用释放钥匙)

A: 机械锁定方式/DC24V电磁线圈解除方式

B: 机械锁定方式/AC110V电磁线圈解除方式

G: DC24V电磁线圈锁定/机械解除方式

L: 机械锁定方式/DC230V电磁线圈解除方式

D: 机械锁定方式/DC24V电磁线圈解除方式(特殊)

6. 指示灯

空白: 无指示灯

A: AC·DC10~115V驱动型(带橙/绿色LED显示单元)

注: 此附录与证书同时使用时有效。



主任:

中国质量认证中心

中国·北京·南四环西路188号9区100070

<http://www.cqc.com.cn>





中国国家强制性产品认证证书

附录:

第 2 页 共 2 页

证书编号: 2003010305073836

纸号: 1069383

D: A C 250V 驱动型 (带橙/绿色氖灯显示单元)

7. 解除钥匙

空白: 有解除钥匙

T: 无解除钥匙

8. 客户编码

空白: 标准产品

#: 面向特定客户 (最大可显示 6 位数字或字母。外观、内部结构均与标准品相同)

注: 此附录与证书同时使用时有效。



主 任:

中国质量认证中心

中国·北京·南四环西路 188 号 9 区 100070

<http://www.cqc.com.cn>

