



中国国家强制性产品认证证书

证书编号: 2003010305086795

委托人名称、地址

欧姆龙自动化(中国)有限公司
上海市外高桥保税区爱都路253号4号楼第4层B1-1部位 200131

生产者(制造商)名称、地址

欧姆龙株式会社
日本京都市下京区盐小路通堀川东入

生产企业名称、地址

东乡电机制作所株式会社
鸟取县东伯郡汤梨浜町大字門田906-1

产品名称和系列、规格、型号

限位开关

D4E; 型号解释详见附录; AC-15: Ue: AC250V, Ie: 2A; AC-14: Ue: AC125V, Ie: 0.5A/0.1A; DC-12: Ue: DC48V/30V/30V, Ie: 2A/0.5A/0.1A; Ith: 5A

产品标准和技术要求

GB 14048.5-2008

上述产品符合强制性产品认证实施规则
CNCA-C03-02: 2014的要求, 特发此证。

发证日期: 2015年06月15日

有效期至: 2020年06月15日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书为变更证书, 证书首次颁发日期: 2003年09月25日

本证书的相关信息可通过国家认监委网站www.cnca.gov.cn查询



主任:

中国质量认证中心

中国·北京·南四环西路188号9区 100070

<http://www.cqc.com.cn>



Q 1151236



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

No. : 2003010305086795

NAME AND ADDRESS OF THE APPLICANT

OMRON INDUSTRIAL AUTOMATION (CHINA) CO., LTD.
4TH FLOOR OF NO. 4 BUILDING, NO. 253 AI DU ROAD, WAIGAOQIAO FREE TRADE
ZONE, SHANGHAI, CHINA (200131)

NAME AND ADDRESS OF THE MANUFACTURER

OMRON CORPORATION
Shiokoji Horikawa Shimogyo-Ku, KYOTO, 600 8530 JAPAN

NAME AND ADDRESS OF THE FACTORY

Togo Electronics Works Co., Ltd.
906-1 Kadota, Yurihama - cho, Tohaku - gun, Tottori - ken, 689 0736,
JAPAN

NAME, MODEL AND SPECIFICATION

Limit Switch

D4E:AC 15:Le:AC250V, Ie:2A;AC 14:Ue:AC125V, Ie:0.5A/0.1A;DC-
12:Ue:DC48V/30V/30V, Ie:2A/0.5A/0.1A;Ith:5A

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB 14048.5-2008

This is to certify that the above mentioned products have met the
requirements of implementation rules for compulsory certification(REF
NO. CNCA-C03-02:2014).

Date of issue: Jun. 15, 2015 Date of expiry: Jun. 15, 2020

Validity of this certificate is subject to positive result of the regular
follow up inspection by issuing certification body until the expiry date.

Date of original certification: Sep. 25, 2003

This certificate can be verified through CNCA's website: www.cnca.gov.cn



President:

Wang Kejiao

CHINA QUALITY CERTIFICATION CENTRE

Section 9, No. 188, Nansihuan Xilu, Beijing 100070 P.R. China

<http://www.cqc.com.cn>



Q 1151236



中国国家强制性产品认证证书

附录:

第 1 页 共 3 页

证书编号: 2003010305086795

纸号: 1151236

型号的解释:

D4E — □ □ □ □ N — □
1 2 3 4 5 6

1. 基本型号

D 4 E: 小型密封型限位开关

2. 额定电流

1: 一般负载型

2: 微小负载型

※具体额定值请参考下页附表

3. 传动装置种类

A: 滚轮柱塞型

B: 交叉滚轮柱塞型

C: 柱塞型

D: 密封滚轮柱塞型

E: 密封交叉滚轮柱塞型

F: 密封柱塞型

G: 滚轮手杆型

H: 单方向动作滚轮手杆型

4. 端子规格

00: AC连接器方式

10: DC连接器方式

20: 螺丝紧固方式 无缆线

注: 此附录与证书同时使用时有效。



主 任:

中国质量认证中心

中国·北京·南四环西路188号9区 100070

<http://www.cqc.com.cn>





中国国家强制性产品认证证书

附录:

第 2 页 共 3 页

证书编号: 2003010305086795

纸号: 1151236

- 21: 螺丝紧固方式 带缆线, 右侧出线
- 22: 螺丝紧固方式 带缆线, 左侧出线
- 23: 带缆线模型, 右侧出线
- 24: 带缆线模型, 左侧出线
- 5. 动作显示灯
 - 空白: 无动作显示灯
 - L: 有动作显示灯 AC250V (霓虹灯)
 - L1: 有动作显示灯 DC12V (LED)
 - L2: 有动作显示灯 DC24V (LED)
 - L3: 有动作显示灯 DC48V (LED)
- 6. 客户编码
 - 空白: 标准产品
 - #: 面向特定客户 (最大可显示 6 位数字或字母, 外观、内部结构均与标准品相同)

※额定值一览表

D1E- ☐ ☐ ☐ ☐ N
1 2 3 4

注: 此附录与证书同时使用时有效。



主 任:

中国质量认证中心

中国·北京·南四环西路 188 号 9 区 100070

<http://www.cqc.com.cn>





中国国家强制性产品认证证书

附录:

第 3 页 共 3 页

证书编号: 2003010305086795

纸号: 1151236

基本型号				使用类别	额定值
1	2	3	4		
1	11	00	-	AC-14	0.5A / 125 VAC
1	□	10	-	DC-12	0.5A / 30VDC
1	11	20,21,22	-	AC-15 DC-12	2A / 250VAC 2A / 48VDC
1	□	23,24	L	AC-15	2A / 250VAC
1	□	23,24	L1	DC-12	2A / 12VDC
1	□	23,24	L2	DC-12	2A / 24VDC
1	□	23,24	L3	DC-12	2A / 48VDC
2	□	00	-	AC-14	0.1A / 125VAC
2	□	10	-	DC-12	0.1A / 30VDC
2	□	20,21,22	-	AC-14 DC-12	0.1A / 125VAC 0.1A / 48VDC
2	□	23,24	L	AC-14	0.1A / 125VAC
2	11	23,24	L1	DC-12	0.1A / 12VDC
2	□	23,24	L2	DC-12	0.1A / 24VDC
2	11	23,24	L3	DC-12	0.1A / 48VDC

注: 此附录与证书同时使用时有效。



主 任:

中国质量认证中心

中国·北京·南四环西路 188 号 9 区 100070

<http://www.cqc.com.cn>

