

# **OMRON**

# **Modification Notice**

**Networks** 

Issue Date September, 2023

Announcement of changes in internal component design to improve parts procurement of parts and conform to the latest DeviceNet specifications.

# [ Target Products ]


- Networks Model DRT2-MD32SLH-1-08
- < Refer to the " [ Details of applicable model ] " . >

#### [ Effective Date ]

Effective as of our production in April, 2024.

#### [ Reason for change ]

To improve parts procurement and conform to the latest DeviceNet specifications.



# [Changes ]

Before the change		After the change	
Model DRT2-MD32SLH-1-08	CIP revision Ver.1.1	Correspondence CIP revision  The CIP revision will be updated to comply with the latest DeviceNet specifications.  Model CIP revision  DRT2-MD32SLH-1-08 Ver.1.2  There is no impact on the operation and performance of this equipment due to the CIP revision.  However, when connecting this equipment to a third-party master, the latest EDS file must be installed on your third-party configurator.  Download the latest EDS file from our website.	
Internal parts		Internal parts  This designing change does not influence any specification, performance, and RoHS certification.	

[Changes]



# [ Details of applicable model ]

**Models / Specification** 

DRT2-MD32SLH-1-08

Specifications in this product news are as of the issue date and are subject to change without notice.

Only main changes in specifications are described in this document. Please be sure to read the relevant catalogs, datasheets, product specifications, instructions, and manuals for precautions and necessary information when using products.