



中国国家强制性产品认证证书

证书编号: 2008010305297698

委托人名称、地址

欧姆龙自动化(中国)有限公司
上海市外高桥保税区爱都路253号4号楼第4层B1-1部位 200131

生产者(制造商)名称、地址

欧姆龙株式会社
日本京都市下京区盐小路通堀川东入

生产企业名称、地址

出云东乡电机株式会社
日本岛根县出云市西林木町626-1

产品名称和系列、规格、型号

开关

A4EG(型号解释详见附录);启动开关部: Ith: 2.5A, Ue/Ie: AC-15: AC125V/1A; DC-13: DC24V/0.3A; 急停开关部: Ith: 5A, Ue/Ie: AC-12: AC125V/5A, AC250V/3A; DC-12: DC30V/3A; 按钮开关部: Ith: 0.1A, Ue/Ie: AC-12: AC125V/0.1A; DC-12: DC30V/0.1A

产品标准和技术要求

GB 14048.5-2008

上述产品符合强制性产品认证实施规则
CNCA-C03-02: 2014的要求, 特发此证。

发证日期: 2015年06月15日

有效期至: 2020年06月15日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书为变更证书, 证书首次颁发日期: 2008年10月14日

本证书的相关信息可通过国家认监委网站www.cnca.gov.cn查询



主任:

中国质量认证中心

中国·北京·南四环西路188号9区 100070

<http://www.cqc.com.cn>



Q 1151235



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

No. : 2008010305297698

NAME AND ADDRESS OF THE APPLICANT

OMRON Industrial Automation (CHINA) Co., Ltd.
B1-1, 4/F, Building 4, No.253 Aidu Road, Waigaoqiao Free Trade Zone,
Shanghai, 200131, P.R.China

NAME AND ADDRESS OF THE MANUFACTURER

OMRON CORPORATION
Shiokoji Horikawa Shimogyo-Ku, Kyoto, Japan

NAME AND ADDRESS OF THE FACTORY

IZUMO TOGO ELECTRONICS Corporation
626-1 Nishihayashigi-Cho Izumo-City Shimane-Pref., 693 0073 Japan

NAME, MODEL AND SPECIFICATION

Switch

A4EG;Start switch:Ith:2.5A,Uc/Ic:AC-15:AC125V/1A;DC-
13:DC24V/0.3A;Emergency stop switch:Ith:5A,Uc/Ic:AC-
12:AC125V/5A,AC250V/3A;DC-12:DC30V/3A;Button switch:Ith:0.1A,Uc/Ic:AC-
12:AC125V/0.1A;DC-12:DC30V/0.1A

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB 14048.5-2008

This is to certify that the above mentioned products have met the
requirements of implementation rules for compulsory certification(REF
NO. CNCA-C03-02:2014).

Date of issue: Jun.15,2015 Date of expiry: Jun.15,2020

Validity of this certificate is subject to positive result of the regular
follow up inspection by issuing certification body until the expiry date.

Date of original certification: Oct.14,2008

This certificate can be verified through CNCA's website: www.cnca.gov.cn



President:

Wang Kejiao

CHINA QUALITY CERTIFICATION CENTRE

Section 9, No.188, Nanshuan Xilu, Beijing 100070 P.R.China

<http://www.cqc.com.cn>



Q 1151235



中国国家强制性产品认证证书

附录:

第 1 页 共 2 页

证书编号: 2008010305297698

纸号: 1151235

型号的解释:

A4EG - □ □ □ □ □ □ - □
1 2 3 4 5 6 7 8

1. 基本形式

A4EG : 抓握式启动开关

2. 启动开关的接点规格

B : 2NO 启动输出
C : 2NO 启动输出 + 1NC 抓握输出

3. 急停开关、其他按钮开关

00 : 无按钮开关
E2 : 急停开关 (2NC 接点)
M2 : 2连按钮开关 (2NC 接点)
P2 : 按钮开关 (2NC 接点)



E2: 急停开关



P2: 按钮开关

→ 黄色按钮 (P2), 不是急停开关。
红色按钮 (E2) 为急停开关。

因此, 用记号予以区别。

4. 按钮开关的颜色

0 : 无按钮开关
R : 红
B : 黑

注: 此附录与证书同时使用时有效。



主 任:

中国质量认证中心

中国 · 北京 · 南四环西路 188 号 9 区 100070

<http://www.cqc.com.cn>





中国国家强制性产品认证证书

附录:

第 2 页 共 2 页

证书编号: 2008010305297698

纸号: 1151235

Y : 黄

5. 橡胶帽

0 : 带橡胶帽

6. 导线管尺寸

4 : M20

7. 导线管连接器

1 : 带导线管连接器

8. 客户号码

空白 : 标准品

: 面向特定客户 (外观、内部结构均与标准品相同)

注: 此附录与证书同时使用时有效。



主 任:

中国质量认证中心

中国 · 北京 · 南四环西路 188 号 9 区 100070

<http://www.cqc.com.cn>

