



中国国家强制性产品认证证书

证书编号: 2003010305064264

委托人名称、地址

欧姆龙自动化(中国)有限公司
上海市外高桥保税区爱都路253号4号楼第4层B1-1部位 200131

生产者(制造商)名称、地址

欧姆龙株式会社
日本京都市下京区盐小路通堀川东入

生产企业名称、地址

出云东乡电机株式会社
日本岛根县出云市西林木町626-1

产品名称和系列、规格、型号

安全门开关

D4GL(型号解释详见附录); Ith: 2.5A; Ue/Ie: AC-15: AC240V/0.75A; DC-13: DC250V/0.27A

产品标准和技术要求

GB 14048.5-2008

上述产品符合强制性产品认证实施规则
CNCA-C03-02: 2014的要求, 特发此证。

发证日期: 2015年07月30日

有效期至: 2020年07月30日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书为变更证书, 证书首次颁发日期: 2003年07月22日

本证书的相关信息可通过国家认监委网站 www.cnca.gov.cn 查询



主任:

中国质量认证中心

中国·北京·南四环西路188号9区 100070

<http://www.cqc.com.cn>



Q 1069382



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

No. : 2003010305064264

NAME AND ADDRESS OF THE APPLICANT

OMRON Industrial Automation (CHINA) Co., Ltd.
B1-1, 4/F, Building 4, No.253 Aidu Road, Waigaoqiao Free Trade Zone,
Shanghai, 200131, P.R.China

NAME AND ADDRESS OF THE MANUFACTURER

OMRON CORPORATION
Shiokoji Horikawa Shimogyo-Ku, Kyoto, Japan

NAME AND ADDRESS OF THE FACTORY

IZUMO TOGO ELECTRONICS Corporation
626-1 Nishihayashigi-Cho Izumo-City Shimane-Pref., 693-0073 Japan

NAME, MODEL AND SPECIFICATION

Safety Door Switch

D4GL;Ith:2.5A;Ue/Ie:AC-15:AC240V/0.75A;DC-13:DC250V/0.27A

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB 14048.5-2008

This is to certify that the above mentioned products have met the requirements of implementation rules for compulsory certification(REF NO. CNCA-C03-02:2014).

Date of issue: Jul.30, 2015 Date of expiry: Jul.30, 2020

Validity of this certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

Date of original certification: Jul.22, 2003

This certificate can be verified through CNCA's website: www.cnca.gov.cn



President:

Wang Kejiao

CHINA QUALITY CERTIFICATION CENTRE

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China

<http://www.cqc.com.cn>



Q 1069382



中国国家强制性产品认证证书

附录:

第 1 页 共 2 页

证书编号: 2003010305064264

纸号: 1069382

型号的解释:

D4GL - □ □ □ □ - □ □ □ - □
1 2 3 4 5 6 7 8 9

1. 基本型号

D4GL: 小型电磁锁定·安全门开关

2. 导线孔尺寸(导管数量)

- 1: PG13.5
- 2: G1/2
- 4: M20

3. 内置开关(检测门开闭状态的开关的接点构成)

- A: 1NC/1NO(慢速)+1NC/1NO(慢速)
- B: 1NC/1NO(慢速)+2NC(慢速)
- C: 2NC(慢速)+1NC/1NO(慢速)
- D: 2NC(慢速)+2NC(慢速)
- E: 2NC/1NO(慢速)+1NC/1NO(慢速)
- F: 2NC/1NO(慢速)+2NC(慢速)
- G: 3NC(慢速)+1NC/1NO(慢速)
- H: 3NC(慢速)+2NC(慢速)
- Q: 3NC(慢速)+1NC(慢速)
- T: 2NC/1NO(慢速)+1NC(慢速)

4. 头部安装方向和头部材质

注: 此附录与证书同时使用时有效。



主任:

中国质量认证中心

中国·北京·南四环西路188号9区 100070

<http://www.cqc.com.cn>





中国国家强制性产品认证证书

附录:

第 2 页 共 2 页

证书编号: 2003010305064264

纸号: 1069382

F: 正面及上面 / 塑料
R: 上面 / 塑料
D: 正面及上面 / 金属
5. 门锁定 / 释放方式

A : 机械锁定方式/DC24V电磁线圈释放方式
G : DC24V电磁线圈锁定方式 / 机械释放方式

6. 指示灯

空白: 无指示灯
A : DC5~24V驱动型 (橙/绿LED显示)

7. 释放钥匙

空白: 一般型
4: 特殊型释放钥匙

8. 内部连接

空白: 串联连接 (11-42)
Z: 无连接 (11-12)、(41-42)

9. 用户编码

空白: 标准品
#: 面向特定用户 (最大可显示 6 位数字或字母) 外观、内部结构均与标准品相同。

注: 此附录与证书同时使用时有效。



主 任:

中国质量认证中心

中国 · 北京 · 南四环西路 188 号 9 区 100070

<http://www.cqc.com.cn>

