



中国国家强制性产品认证证书

证书编号: 2003010305064262

委托人名称、地址

欧姆龙自动化(中国)有限公司
中国(上海)自由贸易试验区爱都路253号4号楼第4层B1-1部位 200131

生产者(制造商)名称、地址

欧姆龙株式会社
日本京都市下京区盐小路通堀川东入

生产企业名称、地址

出云东乡电机株式会社
日本岛根县出云市西林木町626-1

产品名称和系列、规格、型号

安全门开关

D4GS(型号解释详见附件); Ui:250V; Ith:2.5A; Ue/Ie:AC-15:AC240V/0.75A; DC-13:DC250V/0.27A

产品标准和技术要求

GB 14048.5-2008

上述产品符合强制性产品认证实施规则
CNCA-C03-02: 2014的要求, 特发此证。

发证日期: 2016年01月25日

有效期至: 2020年06月15日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书为变更证书, 证书首次颁发日期: 2003年07月22日

本证书的相关信息可通过国家认监委网站www.cnca.gov.cn查询



主任:

中国质量认证中心

中国·北京·南四环西路188号9区 100070

<http://www.cqc.com.cn>



Q 1349500



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

No. : 2003010305064262

NAME AND ADDRESS OF THE APPLICANT

OMRON Industrial Automation (CHINA) Co., Ltd.
B1-1, 4/F, Building 4, No.253 Aidu Road, China (Shanghai) Pilot Free Trade
Zone, 200131, P.R.China

NAME AND ADDRESS OF THE MANUFACTURER

OMRON CORPORATION
Shiokoji Horikawa Shimogyo-Ku, Kyoto, Japan

NAME AND ADDRESS OF THE FACTORY

IZUMO TOGO ELECTRONICS Corporation
626-1 Nishihayashigi-Cho Izumo-City Shimane-Pref., 693-0073 Japan

NAME, MODEL AND SPECIFICATION

Safety Door Switch

D4GS; Ui:250V;Ith;2.5A;Ue/Ie:AC-15:AC240V/0.75A;DC-13:DC250V/0.27A

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB 14048.5-2008

This is to certify that the above mentioned products have met the
requirements of implementation rules for compulsory certification(REF
NO. CNCA-C03-02:2014).

Date of issue: Jan.25,2016 Date of expiry: Jun.15,2020

Validity of this certificate is subject to positive result of the regular
follow up inspection by issuing certification body until the expiry date.

Date of original certification: Jul.22,2003

This certificate can be verified through CNCA's website: www.cnca.gov.cn



President:

Wang Kejiao

CHINA QUALITY CERTIFICATION CENTRE

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China

<http://www.cqc.com.cn>



Q 1349500



中国国家强制性产品认证证书

附录:

第 1 页 共 1 页

证书编号: 2003010305064262

纸号: 1349500

型号的解释:

D 4 G S — N □ □ — □ — □
1 2 3 4 5

1. 基本型号

D 4 G S: 细长型安全门开关

2. 内置开关

- 1 : 1 NC / 1 NO (慢速)
- 2 : 2 NC (慢速)
- 3 : 2 NC / 1 NO (慢速)
- 4 : 3 NC (慢速)

3. 操作钥匙插入方向

- R : 水平方向
- T : 垂直方向

4. 导线长度

- 空白 : 1 m
- 3 : 3 m
- 5 : 5 m

5. 用户编码

空白: 标准品

#: 面向特定用户 (最大可显示 6 位数字或字母) 外观、内部结构均与标准品相同。

注: 此附录与证书同时使用时有效。



主 任:

中国质量认证中心

中国·北京·南四环西路 188 号 9 区 100070

<http://www.cqc.com.cn>

